

# AIRCLEAN

YOUR AIR FILTER MANUFACTURER

P.O. BOX 147,  
MAIDSTONE, ME14 2LA.

TEL:01622 832777  
FAX:01622 832507

[sales@airclean.co.uk](mailto:sales@airclean.co.uk) [www.airclean.co.uk](http://www.airclean.co.uk)

## Cleaning Tanks and Crystals

### Cleaning Crystals

Grease filters should be cleaned regularly and this can be carried out in a number of ways.

Some installations are cleaned under contract by specialist contractors, but the majority of users make arrangements within their own premises for filter cleaning.

Airclean offer a convenient to use alkaline cleaner.

### Series 500 Cleaning Agent

This material is a powerful degreasing agent and its colloidal action removes oil, grease, etc. more efficiently than the usual degreasing agents such as caustic or ordinary washing soda; without the attendant disadvantages of using those materials.

A solution of 500 Cleaner can be kept for several weeks without its efficiency being impaired, so that it need not be discarded until its cleansing power has been fully utilised.

For cleaning grease filters, the solution should be 0.5 kg to 20 litres of water. For best results these crystals should be used with an Airclean Heated Cleaning Tank.

Series 500 is supplied in plastic tubs holding 10kg of cleaning agent..



### Warning

As a precaution for use, if hands are to be immersed in the solution, protective industrial gloves or gauntlets should be worn. Eye protection should be worn also. If the skin becomes splashed, the area should be washed profusely with water.  
Refer to data sheet code Series 500.

### Heated Cleaning Tanks

The above agent can be used in sinks or other containers, but usually means that the solution is discarded after cleaning the grease filter once. With this in mind, Airclean manufacture a vertical design tank, incorporating a heating element, waste valve and lid.

It is manufactured in 1.2mm galvanised sheet steel, with an approximate size of 650mm long x 635mm high x 170mm wide.

The company reserves the right to change specifications without notice.  
E&OE



Code AC3/8 Ref 10/09