






Electrostatic Precipitators, UV Ozone, Atomising Odour Neutraliser

System Maintenance Guidelines			
<p>Electrostatic Precipitator (Grease and Smoke)</p> 		<p>UV Ozone (Odour)</p> 	<p>Atomising Odour Neutraliser (Odour)</p> 
Grease Filters	Washable 3-6 Monthly	<ul style="list-style-type: none"> • Bulb Replacement after 9000hrs (1yr approx) • Bulbs will require a simple "Wipe" 3 monthly 	<ul style="list-style-type: none"> • Fluid Top Up Daily from concentrate. Concentrate typically lasts 1 month depending on concentration required. • Service Advised Yearly
ESP Cells	Washable 3-6 Monthly		
<ul style="list-style-type: none"> • It is recommended that a service contract is considered for ESP cleaning due to fragile cells. • Cells and Grease Filters typically need replacing after 2 years service to maintain efficiency. 			
<p>Approx Replacement Costs Grease Filters : £30 / Filter ESP Cells : £600 / Cell</p>		<p>Approx Replacement Costs Bulbs : £££ POA</p>	<p>Approx Replacement Costs 1 Litre Concentrate : £35</p>

Please Note: Maintenance requirements for all systems can vary depending on the style of cooking and number of covers.

