





Technical Bulletin – Kitchavent System Maintenance Guidelines

Date: 13th June 2022

Kitchavent System Maintenance Guidelines					
Filters	Kitchavent 2000 Light Grease and Odour Control	Kitchavent 3000 Heavy Grease and Odour Control	Kitchavent 4000 Heavy Grease, Smoke and Odour Control	Notes	Approximate Replacement Costs
Mesh Grease Filters 	N/A	Washable Weekly	Washable Weekly	Replacement will be required approx 1-2 years.	£
F5 GP Bag Filters 	Replace 3 Monthly	Replace 3 Monthly	Replace 3 Monthly		£
HEPA Filters 	N/A	N/A	Replace 1-3 Monthly	Spares are recommended to be kept on site.	£££
Activated Carbon 	Replace 6-12 Monthly	Replace 6-12 Monthly	Replace 6-12 Monthly		£££

Please Note: Maintenance requirements for the Kitchavent System can vary depending on the style of cooking and number of covers.